VMS PO

PRODUCT LABEL

SOLENOID DRIVEN METERING PUMPS
WITH DIAPHRAGM

EN

OPERATING MANUAL

This operating instructions contains safety information that if ignored can endanger life or result in serious injury.

Read these instructions **carefully** before use and keep them for future reference. Original instruction.

Information and specifications on this manual could be uncorrect or could have printing errors. Specifications are subject to change without notice.

Version: R1-02-18

Product Description
Descrizione Prodotto

Electromagnetic dosing pump, V and VMS series
Pompa dosatrice elettromagnetiche, serie V e VMS

Product Identification Codes
(the "_" symbols complete the product code based on the configuration of the variants)
Codici Identificativi Prodotto
(i simboli "_" completano il codice del prodotto in base alla configurazione delle varianti)

VAF _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VHD _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VLP _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VAG _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VHE _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VLR _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VAL _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VPV _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VLS _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VAM _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VRE _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VMF _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VAN _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VPX _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VML _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VAO _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VRH _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VMP _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VAP _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VSA _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VMS _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VAR _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VSC _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VMV _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VAS _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VSE _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VNP _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VAU _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VSL _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VNS _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VAV _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VSN _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VNT _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VBA _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VSO _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VOG _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VCD _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VSP _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VOH _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VCL _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VSR _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VOP _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VCO _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VSS _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VOS _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VDA _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VUA _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VP2 _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VDC _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VUG _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VPA _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VDD _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VUL _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VPB _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VDS _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VUM _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VPH _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VEH _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VUS _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VPM _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VEN _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VIP _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VPN _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VER _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VIS _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VPO _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VES _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VLD _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VPP _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VFM _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VLE _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VPS _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
VFS _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	VLG _ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _	

GENERAL SAFETY GUIDELINES

Operating, installing, or maintaining the unit in any way that is not covered in this manual could cause death, serious personal injury, or damage to the equipment.

ICON

This manual use the following safety message icon:

Danger!
Indicates a hazardous situation which, if not avoided, will result in death or serious injury.

Warning!
Indicates a hazardous situation which, if not avoided, could result in death or serious injury.

Important - A practice not related to personal injury or additional information.

Cross reference - An instance which refers to related information elsewhere in the same document

PURPOSE OF USE AND SAFETY

METERING PUMP IS INTENDED FOR CHEMICAL DOSING.

Do not use in explosive area (EX).
Do not use with flammable chemicals.
Do not use with radioactive chemicals.

Use after a proper installation.

Use the pump in accordance with the data and specifications printed on the label.

Do not modify or use in a manner inconsistent with the provisions of the operating manual.

Keep the pump protected from sun and water. Avoid water splashes.

In emergencies the pump should be switched off immediately. Disconnect the power cable from the power supply.

When using pump with aggressive chemicals observe the regulations concerning the transport and storage of aggressive fluid .

When installing always observe national regulations.

Manufacturer is not liable for any unauthorized use or misuse of this product that may cause injury, damage to persons or materials.

Pump must be accessible at all times for both operating and servicing. Access must not be obstructed in any way.

Feeder should be interlocked with a no-flow protection device to automatically shut-off the pumps when there is no flow

Adequate measures shall be taken to prevent cross connection of chemicals!

Chemical feeding must be stopped during backwash cycles and periods of noflow as these conditions may introduce the potential for chemical overdosing. Not doing so may result in elevated chemical concentrations and hazerdous gas introduction into the pool or spa.

Pump and accessories must be serviced and repaired by qualified and authorized personnel only.

Before any operation:

- **always read chemical Material Safety Data Sheet (MSDS);**
- **always wear protective clothing;**
- **always discharge the liquid end before servicing the pump.**
- **empty and rinse the liquid end before work on a pump which has been used with hazardous or unknown chemicals.**

Environmental safety

Work area
Always keep the pump area clean to avoid and/or discover emissions.

Recycling guidelines
Always recycle according to these guidelines:
1. If the unit or parts are accepted by an authorized recycling company, then follow local recycling laws and regulations.
2. If the unit or parts are not accepted by an authorized recycling company, then return them to the nearest representative.

Waste and emissions regulations
Observe these safety regulations regarding waste and emissions:
- Dispose appropriately of all waste.
- Handle and dispose of the dosed chemical in compliance with applicable environmental regulations.
- Clean up all spills in accordance with safety and environmental procedures.
- Report all environmental emissions to the appropriate authorities.

LABEL



Spare parts

For spare parts orders or any other communication, refer to the pump's label.
Code (CODE) and serial number (S / N) uniquely identify the pump.

Transportation and storage

A not suitable transportation or storage can cause damages.

Use origianal box to pack the pump.

Observe storage conditions also for transportation.

Although packed, always protect the unit against humidity and the action of chemicals.

Before return the dosing pump to the manufacturer Repair service, drain the chemical from pump head and rinse it. Refer to Shutdown procedure.

Fill the PRODUCT SERVICE REPAIR FORM and send it with the dosing pump.
Repair service is not accepted if PRODUCT SERVICE REPAIR FORM is missing.

DO NOT TRASH PACKAGING. USE IT TO RETURN THE PUMP.

Transportation and storage temperature ..... 10 - 50°C (32 - 122°F)
Umidity..... 95% relative humidity (not condensed)

Included into package

QUANTITY	CONTENT	**VMS PO**
n. 2	ø6 dibbles	●
n. 2	4,5 x 40 self tapping screws	●
n. 1	5 X 20 delayed fuse	●
n. 1	level probe with axial foot filter (PVDF)	●
n. 1	0,3 bar injection valve (PVDF)	●
m 2	delivery hose (PVDF)	●
m 2	suction hose (PE)	●
m 2	discharge hose (PVC 4x6 transparent)	●
m 2,5	input signal cable	●
n.1	operating manual	●

DESCRIPTION

VMS PO

VMS PO is a proportional dosing pump with level control.
It is driven by internal built-in pH or Redox (ORP) meter (electrode not included).

Ranges:
pH: 0 - 14 pH
ORP: -999mV - +999mV

FEATURES
Select pH or ORP parameter by menu: choose MODE and set pH or ORP.
In both modes, the pump can be set to dose in on / off or proportional.
In On / Off mode, the pump operates in two values (set-point)
In proportional mode the pump doses proportionally into the set point.

Fast calibration
You can performa a fast calibration on standard value.
7.0 and 4.0 for pH, 650 mV for ORP. For different value proceed to a full calibration.

Restore last calibration
If an error occur during calibration you can restore last calibration saved.

Alarms (sold as option, PG7 two wires)
Dosing, reading (probe failure), min and max, level and stand-by.

Alarm output status: N.O. or N.C.

DELAY
Programmable delay at dosing start up.

RESTORE FACTORY
Restore factory value (default value).

PASSWORD AND LANGUAGE
Settable password and language (EN or FR or ES or IT).

STAND-BY
Stand-by INPUT. (default N.O:)

VERIFY CHEMICAL COMPATIBILITY OF PUMP HEAD, O-RING AND HOSES BEFORE USE.

⚠ **Refer to ⎘ Chemical Compatibility table.**

Fig. 2. VMS PO


Display LCD
Delivery valve
Discharge knob
Pump head
Probe input
Stand-by BNC
Level probe input
Alarm Output (PG7 option)
Suction valve
to power supply

Features

Power Supply	Fuse	Frequency
230 VAC (180-270 VAC)	800 mA	50/60 Hz
115 VAC (90-135 VAC)	400 mA	
24 VAC (20-32 VAC)	2 A	
12 VDC (10-16 VDC)	3,15 A	/

Environment temperature ..... 10 - 45°C (32 - 113°F)
Chemical temperature ..... 0 - 50°C (32 - 122°F)
Transportation and storage temperature ..... 10 - 50°C (32 - 122°F)
Installation class II
Pollution level 2
Audible noise ..... 70.4 dbA
Protection degree ..... IP 65 (RU working %: 85% with T<=40°C;
..... 70% T=50°C without condensing water)
Altitude ..... 2000 m AMSL
Dimensions 225x215x125mm
Max installation height ..... 1,5 m
Capacity ..... Table 1-2

Tab. 1. Capacity (manual models)

Model	FLOW			cc per STROKE	pulse/min	Maximum pressure		Hoses	
	min cc/h	max l/h	Max GPH			bar	PSI	delivery (PE)	suction (PVC)
2001	0.09	1	0.26	0.09	180	20	290	4 x 8	4 x 8
1802	0.19	2	0.53	0.19	180	18	261	4 x 8	4 x 8
1804	0.37	4	1.06	0.37	180	18	261	4 x 8	4 x 8
1502	0.19	2	0.53	0.19	180	15	217	4 x 6	4 x 6
1504	0.37	4	1.06	0.37	180	15	217	4 x 6	4 x 6
1505	0.46	5	1.32	0.46	180	15	217	4 x 6	4 x 6
1004	0.37	4	1.06	0.37	180	10	145	4 x 6	4 x 6
1005	0.46	5	1.32	0.46	180	10	145	4 x 6	4 x 6
1010	0.93	10	2.64	0.93	180	10	145	4 x 6	4 x 6
0706	0.56	6	1.58	0.56	180	7	101	4 x 6	4 x 6
0510	0.93	10	2.64	0.93	180	5	72	4 x 6	4 x 6
0512	1.11	12	3.17	1.11	180	5	72	4 x 6	4 x 6
0501	0.09	1	0.26	0.09	180	5	72	4 x 6	4 x 6
0408	0.74	8	2.11	0.74	180	4	58	4 x 6	4 x 6
0310	0.93	10	2.64	0.93	180	3	43	4 x 6	4 x 6
0215	1.39	15	3.96	1.39	180	2	29	6 x 8	6 x 8 (PE)
0116	1.48	16	4.23	1.48	180	1	14	6 x 8	6 x 8 (PE)

Tab. 2. Capacity (self venting models)

Model	FLOW			cc per STROKE	pulse/min	Maximum pressure		Hoses	
	min cc/h	max l/h	Max GPH			bar	PSI	delivery (PE)	suction (PVC)
200.5	0.05	0.5	0.13	0.05	180	20	290	4 x 8	4 x 8
1802	0.19	2	0.53	0.19	180	18	261	4 x 8	4 x 8
1503	0.28	3	0.79	0.28	180	15	217	4 x 6	4 x 6
1501	0.09	1	0.26	0.09	180	15	217	4 x 6	4 x 6
103.4	0.31	3.4	0.9	0.31	180	10	145	4 x 6	4 x 6
1007	0.65	7	1.85	0.65	180	10	145	4 x 6	4 x 6
1002	0.19	2	0.53	0.19	180	10	145	4 x 6	4 x 6
0704	0.37	4	1.06	0.37	180	7	101	4 x 6	4 x 6
057.5	0.69	7.5	1.98	0.69	180	5	72	4 x 6	4 x 6
0509	0.83	9	2.38	0.83	180	5	72	4 x 6	4 x 6
045.5	0.51	5.5	1.45	0.51	180	4	58	4 x 6	4 x 6
0307	0.65	7	1.85	0.65	180	3	43	4 x 6	4 x 6
0212	1.11	12	3.17	1.11	180	2	29	6 x 8	6 x 8 (PE)
0113.5	1.25	13.5	3.57	1.25	180	1	14	6 x 8	6 x 8 (PE)

Materials

✓ : standard
✗: options available

	PVDF	PP	PPV0	PMMA	PVC	PE	CE	VETRO	PTFE	SS	FKM B	EPDM	WAX	SI
BOX		✓	✗											
PUMP HEAD	✓			✗										
DIAPHRAGM									✓					
BALLS							✓	✗	✗	✗				
SUCTION HOSE	✗				✓	✗								
DELIVERY HOSE	✗				✗	✓								
DISCHARGE HOSE	✗				✓	✗								
O RING									✗		✗	✗	✗	✗
LEVEL PROBE/ FOOT FILTER	✓													
LEVEL PROBE CABLE						✓								

INSTALLATION

How to install metering pump

5 steps to install and start-up the pump:

1. Pump location
2. Piping connections (hoses, level probe, injection valve)
3. Wirings
4. Pump priming
5. Programming and start-up

The operator must be aware of safety precautions to prevent physical injury.

User health and safety

POWER SUPPLY DISCONNECTION
Disconnect power supply before you perform any installation or maintenance tasks. Failure to disconnect power will result in serious physical injury.

SAFETY EQUIPMENT
Use safety equipment according to the company regulations. Use this safety equipment within the work area:
- **Helmet**
- **Safety goggles (with side shields)**
- **Protective shoes**
- **Protective gloves**
- **Gas mask**

The work area

THE WORK AREA
Observe these regulations and warnings in the work area:
- **Always keep the work area clean.**
- **Pay attention to the risks presented by gas and vapors in the work area.**
- **Avoid all electrical dangers. Pay attention to the risks of electric shock or arc flash haza ds.**
- **Avoid water splashs and direct sun!**

Pump location

Pump must be installed on a stable support at a max **1,5 mt** height from tank's bottom.

Injection point must be higher than tank to avoid accidental chemical injection.

Otherwise, connect a **multifunction valve** on delivery pipeline.

INSTALLATION PUMP GUIDELINES
Install the pump
- in a safety place and fixed to the table / wall to avoid vib ation problems;
- in an easy accessible place;
- in horizontal position.

Use only hoses compatibles with product to dose.
See "Chemical compatibility table" page 31.
If dosing product is not listed please consult full compatibility table or contact chemical's manufacturer.

Requirements for product positioning

REQUIREMENTS FOR PRODUCT POSITIONING
Only use fasteners of the proper size and material.
Replace all corroded fasteners.
Make sure that all fasteners are properly tightened and that there are no missing fasteners.

Fig. 3. Installation



PIPING CONNECTIONS

Foot filter / Level probe (included only in some models)

Level probe is assembled with a foot filter that avoid sediments priming probles.
Install level probe on the bottom of the tank.
Connect BNC level probe to the pump BNC input.

Warning: If there is a mixer installed into tank, install a suction lance instead of level probe / foot filte .

In case of replacement of level probe parts, follow the diagram below.

Fig. 4. Level probe assembling diagram.



Suction hose connection

Suction piping should be as short as possible and installed in vertical position to avoid air bubbles suction.

Completely unscrew tightening nut from pump's head and remove assembling components: tightening nut, holding ring and pipe holder.
Assembly as shown in fig. 4.
Insert hose into pipe holder until it reaches the bottom. Lock hose on pump's head by screwing down the tightening nut.

Hand-tighten the nuts firml .
Do not use tongs or any other tool.

Fig. 5. Suction hose assembling



Pump head / delivery hose assembling procedure

Suction and delivery valves must be in vertical position.

Delivery hose must be firmly fixed to avoid suddenly movements that coul damage near objects

Completely unscrew tightening nut from pump's head and remove assembling components: tightening nut, holding ring and pipe holder.
Assembly as shown in fig.5.
Insert hose into pipe holder until it reaches the bottom. Lock hose on pump's head by screwing down the tightening nut.

Hand-tighten the nuts firml .
Do not use tongs or any other tool.
Connect the other end of the hose to the injection valve using the same procedure.

Fig. 6. Delivery hose / pump head assembling



Injection valve

Injection valve must be installed on plant from water's input.
Injection valve will open at pressure greater than 0,3 bar.
On request 1, 2, 3, 4 or 5 bar injection valve are available.

Discharge hose

Insert one side of discharge hose into discharge connector as shown in fig below.

Insert other side of discharge hose into product's tank.
During priming procedure product exceeding will flow into tank.

Fig. 7. Manual venting pump head model (VMS PO).



For priming procedure see **PRIMING**.

it's allowed to lightly bend discharge hose.

During calibration procedure ("TEST") insert discharge hose into BECKER test-tube.

VMSA PO self venting pump head connection

Refer to fig. below for delivery and discharge hose.
Assembling procedures are the same described before.

Fig. 8. Self-venting models pump head



Suction, delivery and discharge valve are different.

WIRING

Preliminary checks

THE ELECTRICAL WIRINGS SHOULD BE CARRIED OUT BY AUTHORIZED AND QUALIFIED PERSONNEL ONLY IN ACCORDANCE WITH LOCAL REGULATIONS.

Before to proceed, verify the following steps:

1. **Verify the data on nameplate.**
   Make sure that the electrical data on the nameplate of the motor corresponds to the electrical supply.

2. **Verify the grounded power outlet.**
   The pump must be plugged to a grounded power outlet. Pump must be connected to a motor protection switch (Residual Current Circuit Breaker - MCCB).

3. **Install a relay switch. Do not install it in parallel with heavy inductance load (for example: engines). See fi . below.**

Fig. 9. Electrical installation.



4. **Verify peak Amps. 115 or 230 VAC pumps do not use motor overload protection.**

Power supply	
12 VDC	connect the pump to a 55 Ah-12VDC battery
24 VDC	connect the pump to a 200W stabilized power supply (verify peak Amps)

5. **Verify level probe "BNC" is connected as described in "Foot filter / Level p obe".**

Pump's wiring

Connect pH or ORP probe "BNC" to pump probe input.

Connect level probe to pump level probe input.

Fig. 10. Wirings



PRIMING

Warnings

⚠ **Feeder should be interlocked with a no-flow p otection device to automatically shut-off the pumps when there is no flow**

⚠ **Adequate measures shall be taken to prevent cross connection of chemicals!**

⚠ **Chemical feeding must be stopped during backwash cycles and periods of noflow as these conditions may introduce the potential for chemical overdosing. Not doing so may result in elevated chemical concentrations and hazerdous gas introduction into the pool or spa.**

⚠ **Never operate any pumping system with a blocked suction and discharge. You must take all necessary measures to avoid this condition.**

⚠ **SAFETY EQUIPMENT**
Use safety equipment according to the company regulations. Use this safety equipment within the work area:
- **Helmet**
- **Safety goggles (with side shields)**
- **Protective shoes**
- **Protective gloves**
- **Gas mask**

Pump's priming

To prime the pump:

1. perform al pipings (delivery, suction and discharge hose);
2. turn completely the discharge knob to open discharge valve;
3. supply the pump and turn on
4. set MANUAL (refer to Setting menu).
5. When the product will start to flow into discharge hose, close the discharge valve turning the knob (not for self-venting model).

For viscous liquids, to facilitate priming: insert a 20 cc syringe on venting pipe and suck;
When syringe is almost full close the discharge valve turning the knob..

VMS PO CONTROL PANEL



Keyboard function	▲	SCREENS SCROLL / NUMBER INCREASING
	▶	CHANGE FIELD ON THE SAME SCREEN
	ESC	ON/OFF / EXIT OR BACK WITHOUT SAVE
	E	SELECT / CONFIRM / SAVE

PROGRAMMING THE PUMP

Start/Power off

Connet power supply cable and start the pump with ON/OFF key.
Display will be on (default settings).
At first power on choose language.
Mode OFF: press OFF to switch off the pump.
Unplug power supply to complete the power off.

Default settings

PASSW	PASSWORD	0000
LANG	LANGUAGE	ENGLISH
OUT AL	OUT ALARM	N.O.
STAND-BY	STAND-BY	N.O. - TIME 00 MIN
DOS AL	DOSING ALARM	TIME 0h 00min - STOP no
READ AL	READING ALARM	TIME 0h 00min - STOP no
SET P pH	SETPOINT pH	PROP - pH1 7,5 50% - pH2 7,3 0%
SET P ORP	SETPOINT ORP	PROP - ORP1 700 50% - ORP2 730 0%

Main menu

Use ▲ to scroll main menu.



Tab. 3. Symbols on display

#	one or more alarms occur (see **ALARMS)**.

Press ▲ to delete alarm messages on display.



MODE

Set the pump **working mode** between pH and ORP.

SET P

Set the pump **working mode** between ON/OFF or PROPORTIONAL and the ranges for on/off dosing or proportional dosing. % refer to pump stroke/minute.

In ON/OFF mode the pump works using two set values that enable or disable the pump.
Regulate Low value on 0% for pump off. Only in exceptional cases and for special applications regulate low value on a percentage different from 0%.

If pH pump:



If ORP pump:

Example

Pump working in ON/OFF mode:



In PROPORTIONAL mode the pump works proportionally in the set range.
Regulate Low value on 0% for pump off. Only in exceptional cases and for special applications regulate low value on a percentage different from 0%.

If pH pump:



If ORP pump:

Example

Pump working in PROPORTIONAL mode



FAST CAL

Set FAST CAL to perform a fast calibration on standard value: 7pH and 4ph or 650mV.
In order to perform a fast calibration, you need:

- 7 pH buffer solution
- 4 pH buffer solution

or

- 650 mV buffer solution

If pH pump:



If ORP pump:



CAL

Set CAL to perform a classic calibration on 2 points if pH pump or on 1 point if ORP pump.
In order to perform a complete calibration, you need:

- two pH buffer solutions

or

- a mV buffer solution.

If pH pump:



If ORP pump:



REST CAL

Set REST CAL to restore the LAST calibration saved.

DOS AL

DOSING ALARM set a maximum dosing time alarm (max 9 h 99 min). This alarm prevents the pump to dose if a set time is reached.
If pump doses over the time, an alarm occurs.
If the dosing alarm occurs, the pump can be stopped or not (select STOP YES or NO).

MIN/MAX

MIN/MAX set tha alarm for high and low ORP value. Set a delay to wait a reasonable time before alarm.
The alarm can stop (STOP YES) the pump.

If pH pump:



If ORP pump:



READ AL

READING ALARM set a probe reading alarm (max 9 h 99 min). This alarm prevents against probes failures.
If the value read by probe does not change for the time set, an alarm occurs.
If the reading alarm occurs, the pump can be stopped or not (select STOP YES or NO).



STAND-BY

STAND-BY set an input to stop the pump.
Set a delay (max 99 min) to wait a reasonable time after alert.
The stand by input can be set on:
- N.O.
- N.C.
- Disable

OUT AL

OUT AL set alarm relais status. This contact can be set as:
- N.O. contact;
- N.C. contact.

DELAY

DELAY set a waiting time after pump supply. It is suggested to wait a reasonable time for probe polarization. You can interrupt this delay by pressing **ESC** key to cancel the remaining time. Max delay 99 minutes.

FACTORY

Set FACTORY to restore the default settings (refer to Default settings).

PASSW

Set PASSWORD to change default password (0000).

LANG

Set LANG to change language (ENGLISH, FRENCH, DEUTSCH or SPANISH).

MANUAL

MANUAL set pump manual dosing up to 99 minutes and 99 seconds . This menu allows to prime the pump.



ALARMS

If one or more alarms occur, they are listed on main menu.
Solve the problem and delete the alarm message pressing ▲.



Documented alarms are:

ALARM	CAUSE	SOLUTION	
DOSING	Dosing time over the limit (refer to DOS AL into Setting menu).	Check the probe	Clean and calibrate. Eventually replace with a new probe
		Check pump: no/not enough feeding	Control and clean injection valve Control and clean foot filter Control and clean pump's valves Control solenoid
READING	Probe reading is not reliable. A probe failure is probable (refer to READ AL into Setting menu).	Check the probe	Clean and calibrate. Eventually replace with a new probe
		Check probe holder	Restore flow into probe holder
STAND-BY	No water flow.	Check probe holder	Restore flow into probe holder
		Check the flow into plant	Restore flow into plant
LEVEL	Empty tank	Fill the tank	Restore product into tank
SUPPLY	Supply voltage over the limit (refer to the label)	Check supply voltage	Delete alarm on display pressing ⬆
MIN	pH (or ORP) under min	Alarm disappears when reading is within the set range	
MAX	pH (or ORP) over max	Alarm disappears when reading is within the set range	

Not documented alarms

ALARM	CAUSE	SOLUTION	
PH PROBE READING BLINKS ON DISPLAY	pH over the limit (0/14 pH)	Check probe	Clean and calibrate. Eventually replace with a new probe
		Check pump: too feeding	Control pump settings Control and clean injection valve
ORP PROBE READING BLINKS ON DISPLAY	ORP over the limit (-999/+999 mV)	Check probe	Clean and calibrate. Eventually replace with a new probe
		Check pump: too feeding	Control pump settings Control and clean injection valve

TROUBLESHOOTING

Tab. 5. Guide to troubleshooting

PROBLEM	CAUSE	REMEDY
Pump does not start	• Pump not powered • Protection fuse • Main board	• Collegare la pompa alla rete elettrica • Replace fuse **Fuse replacement procedure**. • Replace main board **Main board replacement procedure**.
Pump does not feed but solenoid runs	• Foot filter obstruction • Pump head empty (suction pipe empty) • Air bubbles into pump head or into suction pipe • Product generates gas	• Clean the foot filter • Prime the pump **PRIMING** • Check valves, pipes and fittings • Open discharge knob and let air flow out. Use a self-venting pump head.
Pump does not feed, solenoid does not run or slightly run	• Valves and/or ball valves blocked • Injection valve obstruction	• Clean valves and ball valve. Feed 2-3 litres of water to wash valves and pump head • Change valves

If the problem can not be solved, please contac after-sales service or return the dosing pump to the manufacturer.

Repair service

Before return the dosing pump to the manufacturer Repair service, drain the chemical from pump head and rinse it. Refer to Shutdown procedure.
If there is the possibility that residual corrosive liquid into pump head could cause damages, declare it on REPAIR FORM.

Fill the PRODUCT SERVICE REPAIR FORM and send it with the dosing pump.
Repair service is not accepted if PRODUCT SERVICE REPAIR FORM is missing.

Fuse replacement procedure

⚠ Make sure that the product is isolated from the power supply and cannot be powered by mistake.

⚠ This procedure SHOULD BE CARRIED OUT BY AUTHORIZED AND QUALIFIED PERSONNEL

In order to replace fuse, you need these tools:
- a 3x16 screwdriver
- a 3x15 screwdriver
- fuse (see **Features**)

- Unplug power supply and pipings.
- Remove screws on the back of the pump.
- Pull back cover until it's completed separated from pump's front. Be careful of the knob's spring.
- Locate the fuse and replace with a new one.
- Reassemble the pump.
- Reinsert screws

Main board replacement procedure

⚠ Make sure that the product is isolated from the power supply and cannot be powered by mistake.

⚠ This procedure SHOULD BE CARRIED OUT BY AUTHORIZED AND QUALIFIED PERSONNEL

In order to replace main board, you need these tools:
- a 3x16 screwdriver
- a 3x15 screwdriver
- new main board.

- Unplug power supply and pipings.
- Remove screws on the back of the pump.
- Pull back cover until it's completed separated from pump's front. Be careful of the knob's spring.
- Remove boards screws..
- Completely disconnect wires from main board and replace it. Reinsert screws.
- Reconnect wires to the main board (Main board scheme).
- Reassemble the pump.
- Reinsert screws.

Main board

Fig. 12. Main board scheme



MAINTENANCE

Maintenance schedule

In order to ensure the requirements of potable drinking water treated and the maintenance of the improvements as declared by the manufacturer, this equipment must be checked at least once a month.

OPERATOR PROTECTION

Use safety equipment according to the company regulations.
Use this safety equipment within the work area during installation, service and when handling chemicals:

- **protective mask**
- **protective gloves**
- **safety goggles**
- **ear plugs or hear muffs**
- **further security device, if necessary.**

POWER SUPPLY DISCONNECTION

Always disconnect power before you perform any installation or maintenance tasks. Failure to disconnect power will result in serious physical injury.

Installation and maintenance tasks should be carried out by AUTHORIZED AND QUALIFIED PERSONNEL only in accordance with local regulations.

Use original spare parts.

Maintenance inspection

Shutdown the dosing pump before any maintenance operation **Shutdown procedure.**

A maintenance schedule includes these types of inspections:

- Routine maintenance and inspections
- Three-month inspections
- Annual inspections

Shorten the inspection intervals appropriately if the pumped chemical is abrasive or corrosive.

Routine maitenance and inspections

Perform these tasks whenever you perform routine maintenance:

- Inspect the seal. Ensure that there are no leaks from the mechanical seal.
- Check electrical wiring
- Check for unusual noise and vibration (noise allowed 73 dbA; ± 5 dB).
- Check the pump and piping for leaks.
- Check for corrosion on parts of the pump and / or on hoses.

Three-month inspections

Perform these tasks every three months:

- Check that the tightenings.
- Check the mechanical seal if the pump has been left idle.

Annual inspections

Perform these inspections one time each year:

- Check the pump capacity (as per nameplate).
- Check the pump pressure (as per nameplate).
- Check the pump power (as per nameplate).

If the pump performance does not satisfy your process requirements, and the process requirements have not changed, then perform these steps:
1. Disassemble the pump.
2. Inspect it.
3. Replace worn parts.

Shutdown procedure

⚠ **This procedure SHOULD BE CARRIED OUT BY AUTHORIZED AND QUALIFIED PERSONNEL**

⚠ **OPERATOR PROTECTION**
Use safety equipment according to the company regulations.
Use this safety equipment within the work area during installation, service and when handling chemicals:
- **protective mask**
- **protective gloves**
- **safety goggles**
- **ear plugs or hear muffs**
- **further security device, if necessary.**

Shutdown the dosing pump **before any maintenance operation** or **before long downtimes**. Disconnect power and ensure it cannot be restarted.

⚠ **Depressurize the system. The liquid may leak splashing.**

Drain the chemical from pump head.
Release the pressure and disconnect the disharge pipe from the discharge valve.
Rinse the pump head and clean all valves.

Delivery curves

Flow rate indicated is for H_2O at 20°C at the rated pressure.
Dosing accuracy ± 2% at constant pressure ± 0,5 bar.

Fig. 13. VMS PO delivery curves

2001: l/h 1 bar 20
Pump head mod. J



1804: l/h 4 bar 18
Pump head mod. K



1802: l/h 2 bar 18
Pump head mod. K



1504: l/h 4 bar 15
Pump head mod. K



1502: l/h 2 bar 15
Pump head mod. K



1010: l/h 10 bar 10
Pump head mod. K



1005: l/h 5 bar 10
Pump head mod. K



1004: l/h 4 bar 10
Pump head mod. K



0706: l/h 6 bar 7
Pump head mod. K



0510: l/h 5 bar 10
Pump head mod. K



0408: l/h 8 bar 4
Pump head mod. K



0310: l/h 10 bar 3
Pump head mod. K



0215: l/h 15 bar 2
Pump head mod. K



0116: l/h 16 bar 1
Pump head mod. K



Fig. 14. VAPO delivery curves

200.5: l/h 0.5 bar 20
Pump head mod. JA



1802: l/h 2 bar 18
Pump head mod. KA



1503: l/h 3 bar 15
Pump head mod. KA

1501: l/h 1 bar 15
Pump head mod. KA



103.4: l/h 3.4 bar 10
Pump head mod. KA



1002: l/h 2 bar 10
Pump head mod. KA



0704: l/h 4 bar 7
Pump head mod. KA



057.5: l/h 7.5 bar 5
Pump head mod. KA



045.5: l/h 5.5 bar 4
Pump head mod. KA



0307: l/h 7 bar 3
Pump head mod. KA



Dimensions

Fig. 15. Dimensions

DIMENSIONS		
	mm	*inch*
A	106.96	4.21
B	210.44	8.28
C	199.44	7.85
D	114.50	4.50
E	187.96	7.40
F	97.00	3.81
G	106.96	4.21
H	125.47	4.93
L	50.00	1.96
M	201.00	7.91



COMPATIBILITY TABLE

Chemical compatibility table

Solenoid driven metering pumps are widely used to dose chemical fluids and it is important that the most suitable material in contact with fluid is selected for each application. This compatibility table serves as a useful help in this respect. All the informations in this list are verified periodically and believed to be correct on the date of issuance. All the informations in this list are based on manufacturer's data and its own experience but since the resistance of any material depends by several factors this list is supplied only as an initial guide, in no way manufacturer makes warranties of any matter respect to the informations provided in this list.

Tab. 6. Chemical compatibility table.

Product	Formula	Ceram.	PVDF	PP	PVC	SS 316	PMMA	Hastel.	PTFE	FPM	EPDM	NBR	PE
Acetic Acid, Max 75%	CH3COOH	2	1	1	1	1	3	1	1	3	1	3	1
Hydrochloric Acid, Concentrate	HCl	1	1	1	1	3	1	1	1	1	3	3	1
Hydrofluoric Acid 40%	H2F2	3	1	3	2	3	3	2	1	1	3	3	1
Phosphoric Acid, 50%	H3PO4	1	1	1	1	2	1	1	1	1	1	3	1
Nitric Acid, 65%	HNO3	1	1	2	3	2	3	1	1	1	3	3	2
Sulphuric Acid, 85%	H2SO4	1	1	1	1	2	3	1	1	1	3	3	1
Sulphuric Acid, 98.5%	H2SO4	1	1	3	3	3	3	1	1	1	3	3	3
Amines	R-NH2	1	2	1	3	1	-	1	1	3	3	1	1
Sodium Bisulphite	NaHSO3	1	1	1	1	2	1	1	1	1	1	1	1
Sodium Carbonate (Soda)	Na2CO3	2	1	1	1	1	1	1	1	2	1	1	1
Ferric Chloride	FeCl3	1	1	1	1	3	1	1	1	1	1	1	1
Calcium Hydroxide (Slaked Lime)	Ca(OH)2	1	1	1	1	1	1	1	1	1	1	1	1
Sodium Hydroxide (Caustic Soda)	NaOH	2	3	1	1	1	1	1	1	2	1	2	1
Calcium Hypochlor.(Chlor. ted Lime)	Ca(OCl)2	1	1	1	1	3	1	1	1	1	1	3	1
Sodium Hypochlorite, 12.5%	NaOCl + NaCl	1	1	2	1	3	1	1	1	1	1	2	3
Potassium Permanganate, 10%	KMnO4	1	1	1	1	1	1	1	1	1	1	3	1
Hydrogen Peroxide, 30% (Perydrol)	H2O2	1	1	1	1	1	3	1	1	1	3	3	1
Aluminium Sulphate	Al2(SO4)3	1	1	1	1	1	1	1	1	1	1	1	1
Copper-II-Sulphate (Roman Vitriol)	CuSO4	1	1	1	1	1	1	1	1	1	1	1	1

1 - Good resistance rating

2 - Fairly resistance rating

3- Not resistant

Materials

Polyvinyldene fluoride (PVDF) .....Pump heads, Valves, Fittings
Polypropylene (PP).....Pump heads, Valves, Fittings
PVC .....Pump heads
Stainless steel (SS 316).....Pump heads, Valves
Polymethyl Metacrilate Acrylic (PMMA) ...Pump heads
Polytetrafluoroethylene (PTFE) .....Diaphragm
Fluorocarbon (FPM).....O-ring
Ethylene propylene (EPDM).....O-ring
Nitrile (NBR).....O-ring

Hose resistance table

Hose features are very important for a reliable dosage. Every pump's model is made to work in the best way using selected hoses according to pump's capacity / model. Information reported here are intended for standard use only. For extended information ask to hose's manufacturer.

Tab. 7. Hoses features

Suction / Delivery Hose			
4x6 mm PVC (transparent)	4x8 mm PE (opaque)	6x8 mm PE (opaque)	8x12 mm PVC (transparent)

Delivery Hose	Working Pressure				Breaking Pressure			
4x6 mm PE 230 (opaque)	20°C 12 bar	30°C 10.5 bar	40°C 8.5 bar	50°C 6.2 bar	20°C 36 bar	30°C 31.5 bar	40°C 25.5 bar	50°C 18.5 bar
4x8 mm PE 230 (opaque)	20°C 19 bar	30°C 15.7 bar	40°C 12 bar	50°C 7.5 bar	20°C 57 bar	30°C 47 bar	40°C 36 bar	50°C 22.5 bar
6x8 mm PE 230 (opaque)	20°C 8.6 bar	30°C 6.8 bar	40°C 4.8 bar	50°C 2.3 bar	20°C 26 bar	30°C 20.5 bar	40°C 14.5 bar	50°C 7 bar
8x12 mm PE 230 (opaque)	20°C 12 bar	30°C 10.5 bar	40°C 8.5 bar	50°C 6.2 bar	20°C 36 bar	30°C 31.5 bar	40°C 25.5 bar	50°C 18.5 bar

4x6 mm PVDF Flex 2800 (opaque)	20°C 40 bar	30°C 34 bar	40°C 30 bar	50°C 27 bar	60°C 24.8 bar	80°C 20 bar	90°C 10 bar
6x8 mm PVDF Flex 2800 (opaque)	20°C 29 bar	30°C 25.5 bar	40°C 22 bar	50°C 20 bar	60°C 18 bar	80°C 14.5 bar	90°C 7.3 bar
8X10 mm PVDF Flex 2800 (opaque)	20°C 18 bar	30°C 15.5 bar	40°C 13.5 bar	50°C 12.5 bar	60°C 11.2 bar	80°C 9 bar	90°C 4.5 bar

1/4 PE 230 (opaque)	20°C 17.6 bar
3/8 PE 230 (opaque)	20°C 10.6 bar
1/2 PE 230 (opaque)	20°C 10.6 bar

PRODUCT SERVICE REPAIR FORM

ENCLOSE THE PRESENT FORM TO THE DELIVERY NOTE

DATE .....

SENDER

Company name.....

Address .....

Phone no. .....

Contact person.....

PRODUCT TYPE (see product label)

DEVICE CODE .....

S/N (serial number).....

OPERATING CONDITIONS

Location/installation description .....

.....

Chemical .....

Start-up (date) ..... Running time (approx. hours).....

REMOVE ALL THE LIQUID INTO THE PUMP HEAD AND DRY IT BEFORE PACKAGING IN ITS ORIGINAL BOX.

DESCRIPTION OF PROBLEM

☐ MECHANICAL

- Wear parts.....
- Brekage/other damages .....
- Corrosion.....
- Other.....

☐ ELECTRICAL

- Connections, connector, cables .....
- Operating controls (keyboard, display, etc.) .....
- Elettronics.....
- Other.....

☐ LEAKS

- Connections.....
- Pump head .....

☐ NOT OR INADEQUATE FUNCTION/OTHER

.....

.....

.....

I declare that the dosing pump is free of any hazardous chemical.

Signature of the compiler

Company stamp

TABLE OF CONTENTS

Sommario

GENERAL SAFETY GUIDELINES 2
PURPOSE OF USE AND SAFETY 3
ENVIRONMENTAL SAFETY 4
LABEL 4
SPARE PARTS 4
Included into package 5
DESCRIPTION 6
VMS PO 6
Features 8
Materials 9
INSTALLATION 10
How to install metering pump 10
User health and safety 10
The work area 10
Pump location 10
Requirements for product positioning 10
PIPING CONNECTIONS 12
Foot filter / Level probe (included only in some models) 12
Suction hose connection 13
Pump head / delivery hose assembling procedure 13
Injection valve 14
Discharge hose 14
VMSA PO self venting pump head connection . 15
WIRING 16
Preliminary checks 16
Pump's wiring 17
PRIMING 18
Warnings 18
Pump's priming 18
VMS PO CONTROL PANEL 19
Keyboard function 19
PROGRAMMING THE PUMP 20
Start/Power off 20
Default settings 20
Main menu 20
Setting menu 21
MODE 21
SET P 21
Example 22
Example 22
FAST CAL 23
CAL 23
REST CAL 24
DOS AL 24
READ AL 24
STAND-BY 24
OUT AL 24
DELAY 25
FACTORY 25
PASSW 25
LANG 25
MANUAL 25
ALARMS 26
TROUBLESHOOTING 28
Repair service 28
Fuse replacement procedure 29
Main board replacement procedure 29
Main board 30
MAINTENANCE 31
Maintenance schedule 31
Maintenance inspection 31
Shutdown procedure 32
Delivery curves 33
Dimensions 36
COMPATIBILITY TABLE 37
Chemical compatibility table 37
Materials 37
Hose resistance table 38

Figures

Fig. 1. VMS PO 7
Fig. 2. Installation 11
Fig. 3. Level probe assembling diagram. 12
Fig. 4. Suction hose assembling 13
Fig. 5. Delivery hose / pump head assembling 13
Fig. 6. Manual venting pump head model (VMS PO). 14
Fig. 7. Self-venting models pump head 15
Fig. 8. Electrical installation. 16
Fig. 9. Wirings 17
Fig. 10. Main board scheme 28
Fig. 11. VMS PO delivery curves 31
Fig. 12. VAPO delivery curves 33
Fig. 13. Dimensions 34

Tables

Tab. 1. Capacity (manual models) 8
Tab. 2. Capacity (self venting models) 9
Tab. 3. Symbols on display 20
Tab. 4. Guide to troubleshooting 26
Tab. 5. Chemical compatibility table. 35
Tab. 6. Hoses features 36

PRECAUTIONS RELATING TO DIRECTIVES, REGULATIONS AND STANDARDS

§ CE/EU and UKCA marking

We guarantee that this product meets the essential requirements of the applicable Directives and Regulations based on the following specifications. Please carefully consider the following specifications for use of the product in European Union member countries and the United Kingdom.

• CE/EU harmonized directives and standards

Directives
DIRECTIVE 2006/42/EC
DIRECTIVE 2014/35/EU
DIRECTIVE 2014/30/EU
DIRECTIVE 2011/65/EU
DELEGATED DIRECTIVE (EU) 2015/863

Harmonized standards
EN ISO 12100
EN 809
EN ISO 20361
EN IEC 61326-1
EN 61010-1
EN IEC 63000

• UKCA harmonized regulations and standards

Regulations
2008 No. 1597
2008 2016 No. 1091
2016 No. 1101
2012 No. 3032

Harmonized standards
BS EN ISO 12100
BS EN 809
BS EN ISO 20361
BS EN IEC 61326-1
BS EN 61010-1
BS EN IEC 63000

Disposal of end-of-life equipment by users

This symbol warns you not to dispose of the product with normal waste. Respect human health and the environment by giving the discarded equipment to a designated collection center for the recycling of electronic and electrical equipment. For more information visit the online site.

When dismantling a pump please separate material types and send them according to local recycling disposal requirements. We appreciate your efforts in supporting your local Recycle Environmental Program. Working together we'll form an active union to assure the world's invaluable resources are conserved.